

MDFR NOTE:  
REVISED PLAN

MDFR NOTE:  
EMERGENCY LIGHTING SHALL COMPLY  
WITH NFPA 101 7.9 AND NEC 700-12(E)

E.C. IS RESPONSIBLE FOR INSTALLATION OF ALL LIGHTING NOT IN DECOR  
CLOUD ELEMENTS. E.C. SHALL BE RESPONSIBLE TO PROVIDE FINAL  
CONNECTION OF CLOUD ELEMENT LIGHTING TO SINGLE POINT  
CONNECTION.

LIGHTS IN CEILING/DECOR CLOUD ELEMENTS INSTALLED IN ELEMENT BY  
E.C.

NOTE: FIXTURES SHOWN ON SCHEDULE MAY NOT BE USED

NO.	QUANTITY	LOCATION	MANUFACTURER / CATALOG NUMBER	DESCRIPTION	LAMP		MOUNTING		VOLT	WATT	REMARKS
					#	TYPE	TYPE	HT.			
EX		VARIES	EXISTING EXISTING	VARIES VARIES	VAR.	VARIES	VARIES VARIES	VARIES	VARIES	VARIES	VARIES
B-1	1	DINING	ACCUSERV 04197-37	RECESSED DN LIGHT	1	COMP. FLOUR	RECESSED ACT CEILING	8'-7 1/2"	120	26	6" RECESSED CAN
B-2	1	DINING	ACCUSERV 04197-37	RECESSED DN LIGHT	1	COMP. FLOUR	RECESSED ACT CEILING	8'-7 1/2"	120	26	4" RECESSED CAN
M6	2	EXTERIOR	ACCUSERV 5247-005	2 LIGHT UP/DOWN WALL SCONCE	2	IR3016	WALL	SEE ELEVATION	120	250	SILVER FINISH

LIGHTING PLAN 1/4"=1'-0" A

GENERAL NOTES

- A. CONFIRM LIGHTING FIXTURE QUANTITIES WITH SUPPLIER.
- B. EMERGENCY AND NORMAL LIGHTING MARKED WITH 'NL' SUBSCRIPT SHALL OPERATE CONTINUOUSLY. PROVIDE UNSWITCHED HOT TO NORMAL AND EMERGENCY BALLAST.
- C. EMERGENCY LIGHTING NOT MARKED WITH 'NL' SUBSCRIPT SHALL OPERATE UNDER CONTROL OF E-MAX ENERGY SAVER PANEL AS INDICATED. PROVIDE UNSWITCHED CONSTANT HOT TO EMERGENCY BALLAST AND SWITCHED HOT TO NORMAL BALLAST.
- D. ALL CONDUITS ENTERING OR LEAVING COOLER/FREEZER SHALL BE PROVIDED WITH SEAL-OFF FITTING WITH COMPOUND PER NEC 300-179).
- E. ALL INTERIOR LIGHTING CIRCUITS TO BE WIRED THRU THE E-MAX ENERGY SAVER PANEL. SEE 14 & 18/E.O.
- F. CONTRACTOR TO FIELD VERIFY CEILING TYPE AND PROVIDE PROPER MOUNTING HARDWARE.
- G. ALL FIXTURES SUPPLIED WITH LAMPS.
- H. ELECTRICAL CONTRACTOR SHALL VERIFY AVAILABLE CIRCUITS IN PANEL LP-1 & REUSE EXISTING CIRCUITS AS AVAILABLE. COORDINATE CIRCUITING WITH ARCHITECT AFTER FIELD VERIFICATION OF PANEL LOADS.

11-29-10	GENERAL REV.
01-05-11	
05-24-11	
11-02-11	
11-16-11	

CONTRACT DATE: 10-19-10  
BUILDING TYPE:  
PLAN VERSION: VISION 20.20  
SITE NUMBER:  
STORE NUMBER: X975-059

KFC  
14790 SW 56 th ST.  
MIAMI, FL.  
VISION 2020 VE  
CONCEPT STORE



LIGHTING  
PLAN AND  
SCHEDULE

E4.0

PLOT DATE: 11-16-11